

**Public Health Engineering Department District Water-
Testing Laboratory Gwalior**
Test Report

Type of sample: Water Sample	Particular of sample : collected / not collected by PHED	
Particular of sender: Principal Sanskar Public School Village Naugaon Post Naugaon , Gwalior (M.P.)		
Sample No.	Place of Collection and Details of Sample	Date of collection
1	School Tubewell	23-04-2024
2	-	-
3	-	-
4	-	-
Particular of Sample :		
Date of Receipt: 23-04-2024	Time of Receipt: 2:00 PM	
Lab Reference No:	Date of Analysis: 25-04-2024	

Nature of Study – Chemical and Bacteriological Analysis

S.N.	Characteristics	Unit	As Per BIS-10500-2012 For Drinking Water		RESULT			
			Acceptable Value	Permissible limit in the absence of alternate source	Sample 1	Sample 2	Sample 3	Sample 4
PHYSICAL TESTE								
1	Turbidity	NTU	1.0	5.0	03	-	-	-
2	Color	Cobalt	5	15	-	-	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionable	-	-	-
4	Temperature	C°	-	-	-	-	-	-
CHEMICAL TESTE								
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	7.0	-	-	-
6	Alkalinity	Mg/L	200	600	290	-	-	-
7	Chlorides (as Cl)	Mg/L	250	1000	54	-	-	-
8	Nitrate as No3	Mg/L	45	45	3.2	-	-	-
9	Total hardness	Mg/L	200	600	360	-	-	-
10	Calcium as Ca	Mg/L	75	200	84	-	-	-
11	Magnesium as mg	Mg/L	30	100	36	-	-	-
12	Iron	Mg/L	0.3	1.0	0.10	-	-	-
13	Free Chlorine	Mg/L	0.2	1.0	-	-	-	-
14	T.D.S.	Mg/L	500	2000	540	-	-	-
15	Fluoride	Mg/L	1.0	1.5	0.28	-	-	-
16	Sulphate sa SO4	Mg/L	200	400	10	-	-	-
BECT. FEACAL TESTE								
17	MPN of coliform	per 100 ml	Nil		Nil	-	-	-
18	Faecal Coliform	Per 100 ml	Nil		Nil	-	-	-

- This report should not be provided partially or fully without approval of signatory authorities for legal purposes.
- It is Recommended that acceptable limit is to be implemented values in excess those mentioned under "Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source, but up to the limits indicated under the "permissible limit in the absence of alternate Source"
- The results refer only to tested samples and parameters tested
- samples will be stored for a period of 10 days from the date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Signature of Analyst
District Lab Gwalior
District Water Testing Lab
P.H.E. Division Gwalior
No. 243 /PHED/ Date :- 26/04/2024

Lab In charge
P.H.E.D. Division Gwalior (M.P.)
P.H.E. Division, Gwalior (M.P)

MANAGER
SANSKAR PUBLIC SCHOOL
Naugaon Distt Gwalior (M.P.)
PIN-474001
CBSE Affl. No.1030763 SCH Code-50729

PRINCIPAL
SANSKAR PUBLIC SCHOOL
Naugaon Distt Gwalior (M.P.)
PIN-474001
CBSE Affl. No.1030763 SCH Code-50729